

Watford Police Station Remodelling

UK & IRELAND Client

Hertfordshire Police and Crime Commissioner

Consultant

AECOM Aldgate Tower 2 Leman Street London E1 8FA United Kingdom Tel +44 (0) 20 7061 7000 www.aecom.com

THIS DRAWING IS TO BE READ FOR SERVICES INFORMATION ONLY.
THIS DRAWING IS TO BE READ FULLY INCONJUNCTION WITH AECOM
MEP SERVICES SCOPE OF WORKS / SPECIFICATION AND SCHEDULES.
THIS DRAWING IS TO BE READ FULLLY INCONJUNTION WITH ALL
RELEVANT DESIGN TEAM DRAWINGS, AND REPORTS WHICH INCLUDE
(BUT NOT LIMITED TO) MEP, CIVILS, STRUCTURAL, ARCHITECTURAL
AND FIRE ENGINEER. AND FIRE ENGINEER.
THIS DRAWING IS TO BE READ IN CONJUNCTION WITH AECOM PH SERVICES DRAWING NOS: WPS-ACM-00-B1-DR-PH-500001 TO 500007

THE SANITATION AND RAINWATER DRAINAGE SERVICES SHALL BE DESIGNED AND INSTALLED STRICTLY IN ACCORDANCE WITH THE REQUIREMENTS OF BS EN 12056 PART 2 / PART AND THE BUILDING REQUIREMENTS OF BS EN 12056 PART 2 / PART AND THE BUILDING REGULATIONS.

WORKS TO EXTERNAL RAINWATER GOODS/GUTTERS AND ROOF OUTLETS WILL BE SPECIFIED IN THE ARCHITECTS/BUILDING PACKAGE. INTERNAL RAINWATER PIPES SHALL BE DETAILED IN MEP PACKAGE.

BRANCH PIPEWORK THAT PASSES THROUGH A FIRE BARRIER OR WALL SHALL BE METALLIC OR INTUMESCENTLY SEALED.

RODDING ACCESS TO BE PROVIDED TO ALL NEW SOIL AND WASTE PIPEWORK AND EXTENDED ABOVE THE FLOOD LEVEL OF ALL FITTINGS WHEREVER POSSIBLE.

THE EXISTING ABOVE GROUND DRAINAGE SERVICES FOUL AND INTERNAL RAINWATER FROM ROOF LEVEL TO BASEMENT INC SHALL BE RETAINED. THE CLIENT HAS ORGAINSED FOR THE PIPEWORK SYSTEMS TO BE CLEANED FULLY AND FLUSHED BEFORE SURVEYING USING VISUAL AND CCTV TECHNIQUES TO CHECK CONDITION OF PIPEWORK, PRESSURE TEST AND RECORD THE ROUTE/ SIZE AND SYSTEM CLASSIFICATION OF THE EXISTING SYSTEMS. ANY DEFECTS FOUND AND REMEDIAL WORKS REQUIRED IN ORDER TO BRING THE SYSTEMS BACK TO A SATISFACTORY WORKING OPERATION SHALL BE IDENTFIED AND CARRIED OUT AS AGREED WITH ENGINEER AND CLIENT ACCORDINGLY, ANY ADDITIONAL REMEDIAL REPAIR WORKS TO EXISTING SERVICES NOT CURRENTLY INDICATED ON THE DRAWINGS SHALL BE INSTRUCTED AGAINST A PROVISIONAL SUM.

EXISTING LOCALISED SOIL AND WASTE SERVICES IN WASHROOMS AND TEA POINTS SHALL BE SITSPED OUT BACK TO THE CONNECTIONS WILL BE REUSED AND NEW PIPEWORK PROVIDED TO SERVE THE NEW FITTINGS LOCALLY AS INDICATED.

EXISTING LOCALISED SOIL AND WASTE SERVICES IN WASHROOMS AND THE MAIN DRAINAGE STACKS. EXISTING BRANCH CONNECTIONS WILL BE REUSED AND NEW PIPEWORK PROVIDED TO SERVE THE NEW FITTINGS LOCALLY AS INDICATED.

THE DOMESTIC WATER SERVICES SHALL BE DEDIGNED AND INSTALLED STRICTLY IN ACCORDANCE WITH REQQUIREMENTS OF PS 8558 ,BS

 THE DOMESTIC WATER SERVICES SHALL BE DEDIGNED AND INSTALLED STRICTLY IN ACCORDANCE WITH REQUUIREMENTS OF BS 8558, BS EN806, THE WATER REGULATIONS AND HSG 274 (L8)
 ALL PIPEWORK/ FITTINGS AND EQUIPMENT IN CONTACT WITH WHOLESOME WATER SHALL BE WRAS APPROVED. SANITARY WARE / BRASSWARE AND EQUIPMENT IN THE TEA POINTS AND KITCHENS SHALL BE AS SPECIFIED BY THE ARCHITECT PACKAGE AND SHALL BE WAS AS APPROVED. LOW POINTS SHALL BE FITTED WITH DRAIN COCKS FOR DRAIN DOWN PURPOSES.

ALL EXISTING VALVES FOUND TO BE INOPERABLE SHALL BE REPLACED.

REPLACED.

16. REPLACEMENT DRV'S ON HWS R SHALL BE SUITABLE FOR DOMESTIC HOT WATER SYSTEMS AND SHALL BE ULTRA LOW FLOW TYPE.

17. THE CONTRACTOR SHALL SUPPLY AND FIT THERMOSTATIC MIXING VALVES ON ALLL WASHBASINS TO LIMIT THE TEMPERATURES TO 41 DEGREES CELSIUS MAXIMUM. TMV'S SHALL BE TMV3 COMPLIANT. WHERE TEMPERATURE LIMITING VALVES ARE NOT FITTED WARNING LABELS STATING, "VERY HOT WATER" SHALL BE FIXED ADJACENT TO THE FITTING. LABELS STATING, "VERY HOT WATER" SHALL BE FIXED ADJACENT TO THE FITTING.

18. THE EXISTING DOMESTIC WATER SERVICES INCLUDING MAINS COLD WATER FROM ROOF LEVEL TO BASEMENT INC SHALL IN GENERAL BE RETAINED UNLESS INDICATED ON THE DRAWINGS. THE PIPEWORK SHALL BE SURVEYED TO CHECK CONDITION OF PIPEWORK, PRESSURE TESTED AND RECORD THE ROUTE' SIZE AND SYSTEM CLASSIFICATION OF THE EXISTING SYSTEMS. ANY DEFECTS FOUND FROM THE SURVEY AND REMEDIAL WORKS REQUIRED IN ORDER TO BRING THE SYSTEMS BACK TO A SATISFACTORY WORKING OPERATION SHALL BE REPORTED BY THE CONTRACTOR AND CARRIED OUT AS AGREED WITH ENGINEER AND CLIENT ACCORDINGLY. ANY REMEDIAL/REPAIRS WORK TO EXISTING SERVICES NOT CURRENTLY INDICATED ON THE DRAWINGS SHALL BE INSTRUCTED AGAINST A PROVISIONAL SUM.

19. THE CONTRACTOR SHALL ENSURE THAT EXISTING PIPEWORK SYSTEMS INCLUDING TANKS SHALL BE FLUSHED AND CLEANED/CHLORINATED TO REMOVE ANY POTENTIAL CONTAMINATION / BACTERILOGIAL PROLIFERATION THAT MAY BE PRESENT IN THE EXISTING SYSTEMS READY FOR RE-USE AND BRING BACK INTO SERVICE.

SERVICE.

J. EXISTING WATER SERVICES FOUND TO BE REDUNDANT SHALL BE STRIPPED OUT AND CAPPED AT THE RESPECTIVE MAINS SUPPLIES LEAVING NO DEAD LEGS.

LEGEND SVP - SOIL VENT PIPE RWP – RAINWATER PIPE FWD – FOUL WATER DRAIN SWD – SURFACE WATER DRAIN WP – WASTE PIPE

RE – RODDING EYE FG – FLOOR GULLY BCWS - BOOSTED COLD WATER SERVICE CWDS – COLD WATER DOWN SERVICE HWSF – HOT WATER SERVICES FLOW HWSR – HOT WATER SERVICES RETURN

MWS – MAINS WATER SERVICE IV – ISOLOATING VALVE TMV – THERMOSTATIC MIXING VALVE DOC - DRAIN OFF COCK PRV – PRESSURE REDUCING VALVE BV – BALLVALVE SV – SOLENOID VALVE DRV – DOUBLE REGULATING VALVE

HL HIGH LEVEL LOW LEVEL FA FROM ABOVE TB TO BELOW FROM BELOW TA TO ABOVE

Issue/Revision

DENOTES PIPE TO BE STRIPPED OUT

Purpose Of Issue

Preliminary Stage 3

Project Number

Domestic Water and Sanitation -Roof Layout

Sheet Number

WPS-ACM-00-03-DR-PH-500005

Rev: T1