**AECOM** 

Pro

Watford Police
Station Remodelling

UK & IRELAND

Hertfordshire Police and Crime Commissioner

Consultant

AECOM
Aldgate Tower
2 Leman Street
London E1 8FA
United Kingdom
Tel +44 (0) 20 7061 7000
www.aecom.com

otes

 THIS DRAWING IS TO BE READ FOR SERVICES INFORMATION ONLY
 THIS DRAWING IS TO BE READ FULLY

INCONJUNCTION WITH AECOM MEP SERVICES SCOPE OF WORKS / SPECIFICATION AND SCHEDULES.

3. THIS DRAWING IS TO BE READ FULLLY INCONJUNTION WITH ALL RELEVANT DESIGN

INCLUDE (BUT NOT LIMITED TO) MEP,
CIVILS,STRUCTURAL,ARCHITECTURAL AND
FIRE ENGINEER.

4. THIS DRAWING IS TO BE READ

TEAM DRAWINGS, AND REPORTS WHICH

INCONJUNCTION WITH AECOM PH SERVICES DRAWING NOS: WPS-ACM-00-B1-DR-PH-500001 TO 500007 INC.

5. AN LPCB APPROVED SPECILAIST SPRINKLER

CONTRACTOR SHALL BE ENGAGED TO CARRY OUT WORKS ON THE EXISTING BASEMENT SPRINKLER SYSTEM WHICH SHALL BE RETAINED. ALL WORKS TO BE IN ACCORDANCE WITH THE REQUIREMENTS OF BS EN 12845 AND THE FIRE STRATEGY.

6. THE CLIENT HAS ARRANGED FOR A FULL

SITE SURVEY, TESTING AND VERIFICATION OF THE EXISTING SYSTEM TO INCLUDE ANY RECOMMENDATION FOR REPAIRS/
MODIFICATIONS AND REMEDIAL WORKS REQUIRED TO BRING THE SYSTEM BACK TO FULL AND SATISFACTORY WORKING OPERATION BY A SPECIALIST SPRINKLER CONTRACTOR. ANY REPAIR AND/OR REMEDIAL WORKS REQUIRED SHALL BE AS AGREED WITH THE ENGINEER AND CLIENT AND INSTRUCTED ACCORDINGLY AGAINST A PROVISIONAL SUM. IT IS ANTICIPATED THAT THE SPRINKLER HEADS SHOULD BE REPLACED AS A MINIMUM HOWEVER CONTRACTOR SHOULD VERIFY.

7. THE HAZARD RATING OF THE EXISTING SYSTEM IS UNKNOW AND THIS SHALL BE CONFIRMED BY THE SPECIALIST CONTRACTOR. IT IS ASSUMED TO BE AN OH2>15M SYSTEM SUITABLE FOR CAR PARK PROTECTION.

8. THE EXISTING FIRE MAIN SUPPLY SHALL BE RETAINED AND REPAIRS TO INSULATION AND TRACE HEATING CARRIED OUT AS REQUIRED TO ENSURE CORRECT OPERATION AND PROTECTION AGAINST FROST DAMAGE.

9. EXISTNG HOSEREELS AS INDICATED ON THE DRAWING SHALL BE STRIPPED OUT AND THE BRANCH SUPPLIES CAPPED OFF AT THE MAINS TO LEAVE NO DEAD LEGS.

10.A WET RISER LANDING VALVE IS INSTALLED ON AN UPSTAND IN THE GROUND FLOOR CAR PARK. THIS SHALL BE RETAINED AND RESTORED TO FULL WORKING OPERATION INCLUDING INSULATION/WATERPROOFING AND TRACE HEATING. TO BE CONFIRMED IN THE FIRE STRATEGY.

Issue/Revision

 T1
 23/06/22
 Tender Issue
 DR/LH/BD

 PT1
 10/06/22
 Pre Tender Issue

 Rev.
 Date
 Description
 Drn/Chk/Apr

 Key Plan

Purpose Of Issue

Preliminary Stage 3
Project Number

Sheet Title
Fire Protection/Sprinklers Ground FLoor Layout

Sheet Number

WPS-ACM-00-00-DR-PH-500007

Rev: T1