

- Notes
1. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL OTHER DOCUMENTATION.
 2. IT IS GENERALLY INTENDED THAT THE EXISTING LTHW HEATING, CHILLED WATER & DOMESTIC HOT WATER SERVICES PLANT AND EQUIPMENT WILL ALL BE REPLACED AS PART OF THE CONTRACT WORKS FROM THE POINTS OF CONNECTION TO THE EXISTING PIPE WORK RISERS AT THEIR ENTRY/EXIT TO THE ROOF PLANT ROOM.
 3. GENERALLY THE LOCATION OF THE NEW PRIMARY EQUIPMENT IS TO BE SIMILAR TO THE EXISTING HOWEVER THE CONTRACTOR SHALL BE RESPONSIBLE FOR DEVELOPING THE PLANT ROOM LAYOUT OF ALL ANCILLARY EQUIPMENT, INCLUDING VALVES, FITTINGS ETC, TO ACHIEVE THE BEST POSSIBLE LAYOUT FOR SERVICING & MAINTENANCE PURPOSES. THE CONFIGURATION AND LAYOUT OF THE PLANT & EQUIPMENT TO BE AS SHOWN ON THE SCHEMATIC.
 4. AAVs TO BE LOCATED AT ALL HIGH POINTS AND DCs AT ALL LOW POINTS.

Issue/Revision

T1	23/06/22	Tender Issue	DR/LHB/D
PT1	10/06/22	Pre Tender Issue	DR/LHB/D
Rev.	Date	Description	Drn/Chk/Apr

Key Plan

Suitability Status

S0 - Initial Status

Project Number

60671544

Sheet Title

Mechanical Roof
Proposed Heating and Cooling
Schematic

Sheet Number

WPS-ACM-XX-XX-DR-ME-340101

Scale: NTS@A1 Rev: T1

This drawing has been prepared for the use of AECOM's client. It may not be used, modified, reproduced or relied upon by third parties, except as agreed by AECOM or as required by law. AECOM accepts no responsibility, and denies any liability, whatsoever, to any party that uses or relies on this drawing without AECOM's express written consent. Do not scale this document. All measurements must be obtained from the scaled dimensions.

