Watford Police Station Remodelling

UK & IRELAND Client

Hertfordshire Police and Crime Commissioner

Consultant

AECOM Aldgate Tower 2 Leman Street London E1 8FA United Kingdom Tel +44 (0) 20 7061 7000 www.aecom.com

1. ALL SERVICES DRAWINGS TO BE READ IN CONJUNCTION WITH OTHER DISCIPLINE DRAWINGS, SCHEDULES AND SPECIFICATIONS. 2. DO NOT SCALE FROM THIS DRAWING. 3. SHOULD ANY DISCREPANCIES BE FOUND WITH THIS DRAWING AND ANY OTHER ASSOCIATED DRAWINGS/SPECIFICATIONS/REPORTS, THIS SHOULD BE BROUGHT TO THE ATTENTION OF ENGINEER IMMEDIATELY. 4. THIS DRAWING SHALL ONLY BE USED FOR THE SPECIFIC SERVICES INTENDED. 5. UNLESS OTHERWISE STATED, ALL MEASUREMENTS IN MILLIMETERS. 6. THE MEP SYSTEMS SHALL COMPLY WITH THE RELEVANT STANDARDS DESCRIBED IN THE SPECIFICATION. 7. LOCATIONS OF ALL SERVICE PROVISIONS ARE INDICATIVE. ALLOW FOR RELOCATIONS

AND SETTING OUT OF SERVICES TO BE AGREED WITH ARCHITECT. 8. ALL SOCKET OUTLETS SHALL BE LABELLED WITH THE APPROPRIATE CIRCUIT 9. ALL SOCKET OUTLETS SHALL BE PROTECTED BY RCBO'S LOCATED IN THE DISTRIBUTION BOARD UNLESS OTHERWISE 10. WBC FITOUT CONTRACTORS TO LIAISE WITH THE MAIN CONTRACTOR TO COORDINATE SERVICES ON THE ROOF AREA. EARTH AND LIGHTNING PROTECTION BONDING IS TO BE PROVIDED BETWEEN THE SATELLITE/AERIAL EQUIPMENT AND EXISTING SYSTEMS.

WITHIN A 2 METRE RADIUS. FINAL ACCESS

Issue/Revision

Suitability Status

S0 - Initial Status **Project Number**

Small Power & Ancillaries Layout Basement Floor Layout

Sheet Number

WPS-ACM-00-B1-DR-EL-421001