



| PUMPS | | | | | |
|--------------------|-------------|------------------|----------|----------------------|--|
| HEATING NORTH ZONE | PULLEN | SK32 | 0.61/s | 24 KN/m ² | |
| HEATING SOUTH ZONE | PULLEN | SK32 | 0.67/s | 21 KN/m ² | |
| DHW PRIMARY | HILL FOSTER | MX130A | VARIABLE | | |
| DHW SECONDARY | HILL FOSTER | BRONZE GLANDLESS | 20mm | | |

| CONTROLS (SATCHWELL) | | | | | |
|----------------------|------------|--|--|--|--|
| NORTH ZONE | 1N° MB1552 | 3 PORT VALVE WITH XRM 1201 | | | |
| | | MODULATING ACTUATOR, DW 1204 IMMERSION | | | |
| | | DETECTOR AND DO 2202 OUTSIDE DETECTOR | | | |
| | | DUTY 0.5936 Kg/s - 0.0317 bar | | | |
| SOUTH ZONE | DITTO | DUTY 0.664 Kg/s - 0.0396 bar | | | |
| DHW | 1N° MB1502 | 3 PORT VALVE WITH RM1601 | | | |
| | | ACTUATOR AND WT 2251 IMMERSION STAT | | | |

9-10-78 VENTILATION AND 50 FIRE SUPPLY ADDED
DATE REVISION A

MAUDSLEY HOSPITAL

O.T. DEPARTMENT

**EXTENSION OF ASSESSMENT
UNIT**

**SCHEMATIC/DETAIL OF PLANT
ROOM**

scale 1: 20
date 29.3.78
drawing no. M/ OT/202 A
drawn by. *WJ*

GROUP ENGINEERS DEPARTMENT
BETHLEM ROYAL HOSPITAL
MONKS ORCHARD ROAD
BECKENHAM
KENT BR3 3 BX